



**CSI TESTING**

14020 23rd Avenue N., Plymouth, MN 55447

(763) 383-9535 • Facsimile (763) 383-9546

*Clean Environment Testing Since 1975*

## CERTIFICATE OF COMPLIANCE

**QMR Plastics  
10206 Crosstown Circle  
Eden Prairie, Minnesota 55344**

**March 5, 2008**

<b>Clean Area Description</b>	<b>Clean Area Status</b>	<b>Clean Area Class</b>
Assembly CE	Operational	10,000 / ISO 7
Gown Room	Operational	100,000 / ISO 8

Per the results of the particle count testing, the class is considered met if the measured particle concentration is within the limits specified per Federal Standard 209E, page 5, table 1, and ISO 14644-1 (1999), as determined by the statistical analysis. Particle counts were sampled and reported in the cumulative mode for sizes 0.5  $\mu\text{m}$ , 1.0  $\mu\text{m}$ , and 5.0  $\mu\text{m}$  at a flow rate of 1 cubic foot per minute.

CSI Testing, Inc. certifies that the above referenced clean area has been tested and meets or exceeds the stated class conditions in accordance with Federal Standard 209E and ISO 14644-1 (1999), as noted above on this test date. CSI Testing, Inc. makes no other warranties, stated or implied, concerning the continued performance, operation or safety in use of the clean spaces listed above.

Submitted and Certified by:  
CSI Testing, Inc.

*Carl LaBella/BU*

Carl LaBella  
President