



Minnesota Rubber & Plastics, Quadion LLC
1100 Xenium Lane North
USA – 55441 Minneapolis

OFI Technologie & Innovation GmbH
Firmensitz: 1030 Wien, Arsenal, Franz-Grill-Straße 5
t: +43 1 798 16 01 - 0 | office@ofi.at | www.ofi.at

Test Certificate

based on Elastomer Guideline

„Guideline for Hygienic Assessment of Elastomer Materials in Contact with Drinking Water” (Issue 2016)

Manufacturer: Minnesota Rubber & Plastics, Quadion LLC, USA – 55441 Minneapolis
Product(s): O-Rings
Material: 558CH
Test: initial test according to Elastomer Guideline

According to OFI test report 1801524 / 5543 / 1H dated 2018-10-18 the above mentioned products underwent all tests required by the Elastomer Guideline. They fulfilled the requirements for the following temperature and application areas.

Application - category	Cold water (23 ± 2) °C	Warm water (60 ± 2) °C	Hot water (85 ± 2) °C
Pipes with DN < 80 mm (domestic installation)	---	---	---
Pipes with 80mm ≤ DN ≤ 300mm (supply pipes)	---	---	---
Pipes with DN ≥ 300mm (main pipes)	---	---	---
Fittings (domestic installation)	---	---	---
Fittings (supply pipes)	---	---	---
Fittings (main pipes)	---	---	---
Seals (domestic installation)	fulfilled	---	fulfilled
Seals (supply pipes)	fulfilled	---	fulfilled
Seals (main pipes)	fulfilled	---	fulfilled
Tanks in domestic installations including repair systems	---	---	---
Tanks outside domestic installations including repair systems	---	---	---

The **validity of this test certificate** ends with **2021-12-31** – this under the presumption that no changes in the production or manufacturing process or the basic material are made, with the exception of routine adjustments; in case of changes in the relevant legislations and/or normative regulations, which require a new test on the product, this test certificate loses its validity.

Vienna, 2018-10-18


Christoph Wirrer
Director in charge
Material in contact with drinking water